

Office of the Executive Engineer (Electric)
Distribution South Div, NDMC,
33 KV ESS Kidwai Nagar (West)
New Delhi-110023
Phone No. : 24105953
(E-mail ID: cecds.elect@ndmc.gov.in)

No. D- 1467 /EE(D/S)/2024-25

Date: 22 /08/2024

Executive Engineer (Elect.)
DED-102, CPWD, I.P.Bhawan,
New Delhi-110002

Subject:- Sanction of Grid Connected Net Metering of Roof Top Solar Power Plant, Capacity 22.8 KWp, Installed at Roof Top of 7, Tughlak Road, New Delhi.

Name of Electricity Consumer: Executive Engineer (Elect.) CPWD, C. No. 5013015, K. No. K104030, Sanctioned Load 30 KW.

Sir,

With reference to your application for the subject cited matter, it is to inform that the Net Metering feasibility for renewable energy source of Solar Power Plant 22.8 KWp capacity has been accepted by the Competent Authority at **Roof Top of 7, Tughlak Road, New Delhi** under **Domestic** Category on the basis of requisite documents & fees deposited as under.

1. Approved renewable generation capacity (peak) of Solar Power Plant **22.8 KWp**.
2. Reference of processing fee of Rs. 500/- deposited through Challan No. 206760663 dated 03.07.2024.
3. Reference of registration fee of Rs. 3000/- Challan No. 206764367 dt. **05.8.2024**

The sanction of renewable energy source of Solar System is on the following conditions.

6. There would be no voltage fluctuation on account of integration of Solar Power in NDMC system.
7. There would be no introduction of harmonics in the system.
8. The supply system would remain stable with integration of Solar Power.
9. That Solar Project is installed confirming to DERC/CEA guidelines and meet all regulatory requirements. In case any disturbance are caused in the supply system due to poor workmanship/quality in the Solar Power Plant, NDMC shall not be held responsible.
10. The earthing result of Solar Plant should be within limit.

The installed Solar Power system is technically suitable for "Net Metering" in NDMC supply grid to Import and Export the power supply through the existing LT network as approved by the competent authority.

You are therefore, requested to please contact in the office of **EE (Comml): Shaheed Bhagat Singh Place, Gole Market, New Delhi** for installation of Net Meter after completing the further formalities in their office.

(Er. Sundeep Gaur)
Executive Engineer (E) D/S

Copy to:-

1. CEE-II : For kind information please.
2. Director (Comml.) : for kind information please.
3. SEE-III : for kind information please.
4. Dir. (IT) : with request to upload on NDMC website.
5. EE (Comml): Shaheed Bhagat Singh Place, Gole Market, New Delhi : For information to install the Net Meter please.
6. AEE-(D/S) : For information please.
7. Office copy